

PORTSMOUTH WATER AND FIRE DISTRICT 2021 CONSUMER CONFIDENCE REPORT

Dear Customer:

We are pleased to present a summary of the quality of the water provided to District customers during the past year. The federal Safe Drinking Water Act (SDWA) requires that water utilities issue an annual "Consumer Confidence" report to customers in addition to other notices that may be required by law. This report details where our water comes from, what it contains, and the risks that our water testing and treatment are designed to prevent. The Portsmouth Water and Fire District is committed to providing you with the safest and most reliable water supply available. Informed consumers are our best allies in maintaining safe drinking water.

The Portsmouth Water and Fire District's drinking water meets or exceeds all federal and state drinking water standards.

About the Portsmouth Water and Fire District

The Portsmouth Water and Fire District is a quasi-municipal agency created by the RI General Assembly in 1952. The District is responsible for providing drinking water and water for fire protection for approximately ninety percent of Portsmouth on Aquidneck Island. The District is governed by a seven-member elected Administrative Board and holds an annual election of officers on the second Wednesday in June. The District is not part of the Town of Portsmouth government. However, the District and Town work together to best serve their common constituents.

The original District was known as *Island Park and Common Fence Point Fire District* and its water distribution system was constructed in the mid to late 1950's. In 1956, the name of the District was changed to *Portsmouth Water and Fire District*. In 1965, the District boundaries were changed to include the south end of Portsmouth and the water distribution system was expanded to cover this area in the mid to late 1960's. The Redwood Farms and Raytheon areas were excluded from the District's expanded service area as they were already served by Newport Water. Today the District's water system maintains 6,760 services and consists of over 132 miles of water main, 4 water storage tanks, 2 pumping stations, 1,749 valves and 602 hydrants.

The District does not own any water supplies, but instead purchases its regular water supply on a wholesale basis from the City of Newport and relies on the Stone Bridge Fire District in Tiverton for emergency water supply.

The Administrative Board's goal is to provide the customers of the District with an adequate supply of the best quality water available. Recent and current efforts to improve water quality and customer service include:

- Web Portal that allows customers to pay their water and tax bills on-line using ACH drafts and credit and debit cards. **Go to portsmouthwater.org and click on the "PAY MY BILL" button.**
- Development of a Geographic Information System (GIS) for water system mapping and data analysis.
- Purchase of an Asset Management System web application/server that integrates GIS for record keeping and real-time mobile work orders.
- Construction of a new pump station to replace the 54-year-old Union Street Pumping Station.
- Annual uni-directional water main flushing program based on hydraulic modeling and analysis.
- Looping of new and existing water main extensions whenever possible to avoid dead-ends.
- Implementation of a cross-connection control program.
- Cleaning and inspection of the Sakonnet River Pipeline which is the emergency connection to Stone Bridge Fire District.
- Notifying customers of shut downs and emergencies via CodeRED. **Go to <https://portsmouthwater.org/codered-emergency-notification-system/> to learn more and to sign up.**

We encourage public interest and participation in our community's decisions affecting drinking water. Regular meetings of the Administrative Board of the Portsmouth Water and Fire District are held on the third Tuesday of every month at 7:00 PM, at the District's office at 1944 East Main Road and via Zoom. The public is welcome and encouraged to attend these meetings. Written minutes of the meetings are available upon request. This Consumer Confidence Report and minutes of Board meetings are also available at <https://portsmouthwater.org>

Your Water Source

In 2021, the Portsmouth Water and Fire District purchased all of its water from the City of Newport. The majority of the water is treated at the Lawton Valley Water Treatment Plant in Portsmouth. On occasion, the water may be treated at the Station One Water Treatment Plant in Newport. Newport Water draws its raw water supply from a system of nine surface water reservoirs: Lawton Valley Reservoir, Sisson Pond and St. Mary's Pond in Portsmouth; Nonquit Pond in Tiverton; Watson Reservoir in Little Compton; North and South Easton Ponds in Middletown and Newport; and Paradise Pond and Gardner Pond in Middletown. Both plants and all nine reservoirs are owned and operated by the City of Newport. The emergency supply from the Stone Bridge Fire District is treated at the Stone Bridge Water Treatment Plant in Tiverton, which draws surface water from Stafford Pond in Tiverton.

Source Water Assessments

In 2003, the University of Rhode Island, in cooperation with the RI Department of Health (RIDOH) and other state and federal agencies, assessed the threats within the watersheds of Newport Water's water supply sources. The assessment found that the water sources on Aquidneck Island and in Little Compton and Tiverton are moderately susceptible to contamination. Monitoring and protection efforts are especially important to assure continued water quality. Newport Water updated the 2003 Assessment in 2010. The complete Source Water Assessment Report is available at our office.

Additional Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems;
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Concerning Lead in Our Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Portsmouth Water and Fire District is responsible for providing high quality drinking water, but cannot control the variety of materials used in its customer’s plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap until the water gets as cool as it can and then flush it for another 15 seconds before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your tap water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Although there is no lead in the water supplied by the District, lead can enter tap water through corrosion of household plumbing materials. Homes built before 1986 are more likely to have fixtures and solder containing lead. However, new homes are also at risk: even legally “lead-free” plumbing may contain up to 8 percent lead. The most common problem is with brass or chrome-plated brass faucets and fixtures which can leach significant amounts of lead into the water, especially hot water.

**THE DISTRICT CAN HELP YOU OBTAIN A
CERTIFIED LEAD TEST FOR YOUR TAP WATER FOR \$23.
 PLEASE CALL 683-2090 FOR MORE INFORMATION.**

Newport Water System Special Monitoring – Metals and Synthetic Organic Compounds

As part of Newport Water’s ongoing monitoring programs, they have continued testing sites for metals and synthetic organic compounds every quarter in 2021. The sample sites include: Station 1 total plant effluent, Lawton Valley clearwell tank effluent, and Lawton Valley tank effluent. This represents the water produced at both water plants, after treatment, to the distribution system. Eleven metals and thirty-six organic compounds were analyzed. The table presents only contaminants that were detected.

| Station 1 TPE metals | Unit | MCL | Detected Level | Range | Major Source |
|---|-------------|------------|-----------------------|---------------|--|
| Barium | ppm | 2 | 0.011 | 0.006 - 0.011 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Nickel | ppm | n/a | 0.007 | ND – 0.007 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Lawton Valley clearwell metals | Unit | MCL | Detected Level | Range | Major Source |
| Barium | ppm | 2 | 0.008 | 0.002 - 0.008 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Lawton Valley tank effluent metals | Unit | MCL | Detected Level | Range | Major Source |
| Barium | ppm | 2 | 0.008 | 0.002 - 0.008 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Station 1 TPE Synthetic Organics | Unit | MCL | Detected Level | Range | Major Source |
| Methoxychlor | ppb | 40 | 0.1 | ND – 0.1 | Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock |
| Di(2-ethylhexyl)phthalate | ppb | 6 | RAA=0.25 | ND – 1.0 | Discharge from rubber and chemical factories |
| Lawton Valley clearwell Synthetic Organics | Unit | MCL | Detected Level | Range | Major Source |
| Methoxychlor | ppb | 40 | 0.1 | ND – 0.1 | Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock |
| Di(2-ethylhexyl)phthalate | ppb | 6 | RAA=2.0 | ND – 7.0 | Discharge from rubber and chemical factories |
| Lawton Valley tank effluent Synthetic Organics | Unit | MCL | Detected Level | Range | Major Source |
| Methoxychlor | ppb | 40 | 0.1 | ND – 0.1 | Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock |

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Questions

The Portsmouth Water and Fire District prepared this report. We'll be happy to answer any questions about the District and our drinking water quality. Please contact Jessica Lynch, General Manager and Chief Engineer (401-683-2090).

Some water customers of the Newport Water Department and the Naval Station Newport water system, particularly in the Redwood Farms, Bay View and Melville areas, in addition to properties in the District with private wells, may receive this consumer notice, even though they are not customers of the District. This over-coverage is unavoidable in our effort to ensure that all potential water users within the District receive this legal notice through a Postal Customer mailing.

The Portsmouth Water and Fire District is a proud member and supporter of the American Water Works Association, the New England Water Works Association and the Rhode Island Water Works Association.

PLEASE REFER TO THE WATER QUALITY TABLE BELOW

How Do I Read This Water Quality Table?

It's easy! Our water is regularly tested to assure that it is safe and healthy. The column marked Detected Level shows the highest test results during the year. The column marked Major Sources in Drinking Water shows where substances usually originate. Footnotes explain important details. Abbreviations and definitions of key terms are shown in the table below:

Abbreviations and Definitions used in the Water Quality Tables

| | |
|--------------|---|
| AL | Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| MCL | Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| MCLG | Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MFL | Million Fibers per Liter |
| MRDL | Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MRDLG | Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Mrem | Millirems: a measure of radiation absorbed by the body. |
| N/A | Not Applicable. |
| ND | Not Detectable: Not detectable at testing limits. |
| NTU | Nephelometric Turbidity Units: a measure of very small particulate matter in drinking water. |
| pCi/l | Picocuries per liter: a measure of radioactivity. |
| ppb | parts per billion, or micrograms per liter ($\mu\text{g/l}$). |
| ppm | parts per million, or milligrams per liter (mg/l). |
| ppt | parts per trillion, or nanograms per liter (nanograms/l). |
| RAA | Running Annual Average |
| TT | Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |

PORTSMOUTH WATER AND FIRE DISTRICT

PUBLIC WATER SYSTEM # RI1592022

2021 WATER QUALITY TABLE *

| DETECTED CONTAMINANTS | YEAR TESTED | UNIT | MCL / MRDL | MCLG / MRDLG | DETECTED LEVEL (FOR COMPLIANCE) | DETECTED RANGE | MAJOR SOURCES IN DRINKING WATER | VIOLATION |
|--|-------------|---------------------------------|---|--------------|---------------------------------|----------------|---|-----------|
| Microorganisms | | | MCL | MCLG | | | | |
| Total Coliform Bacteria (1) | 2021 | % of Positive Samples per Month | TT | N/A | 0% | N/A | Naturally present in the environment. | NO |
| Total Organic Carbon (2) | 2021 | Removal Ratio | TT | N/A | 1.27 | 1.11 – 1.53 | Naturally present in the environment. | NO |
| Turbidity (2)(3) | 2021 | NTU | TT = 1.0 Lowest monthly % of samples meeting limit | N/A | 0.28 100% < 0.3 | N/A | Soil runoff. | NO |
| Disinfection Byproducts | | | MCL | MCLG | | | | |
| Chlorite (2) | 2021 | ppm | 1.0 | 0.8 | 0.253 | <0.010 – 0.330 | By-product of drinking water chlorination. | NO |
| Haloacetic Acids (HAA5s) | 2021 | ppb | 60 | N/A | 17.6 | 5.90 – 20.1 | By-product of drinking water chlorination. | NO |
| Total Trihalomethanes (TTHMs) (4) | 2021 | ppb | 80 | N/A | 60.6 | 22.5 – 69.6 | By-product of drinking water chlorination. | NO |
| Disinfectants | | | MRDL | MRDLG | | | | |
| Chlorine | 2021 | ppm | 4 | 4 | 1.16 | 0.47 – 2.03 | Water additive used to control microbes. | NO |
| Chlorine Dioxide (2) | 2021 | ppb | 800 | 800 | 520 | 20 – 520 | Water additive used to control microbes. | NO |
| Inorganic Chemicals | | | MCL | MCLG | | | | |
| Arsenic (5) | 2021 | ppb | 10 | 0 | 0.001 | ND – 0.001 | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production waste. | NO |
| Barium (6) | 2021 | ppm | 2 | 2 | 0.010 | 0.003 – 0.010 | Erosion of natural deposits; discharge of drilling wastes. | NO |
| Copper (7) | 2021 | ppm | AL = 1.3 | 1.3 | 0.047 | N/A | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. | NO |
| Fluoride (2) (8) | 2021 | ppm | 4 | 4 | 0.99 | 0.05 – 0.99 | Water additive, promotes strong teeth. | NO |
| Lead (9) | 2021 | ppb | AL = 15 | 0 | 3.6 | N/A | Corrosion of household plumbing systems; erosion of natural deposits. | NO |
| Nitrate (5) | 2021 | ppm | 10 | 10 | 1.13 | 0.25 – 1.13 | Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits. | NO |
| Asbestos | 2020 | MFL | 7.0 | 7.0 | <0.062 | n/a | Decay of asbestos cement in water mains; erosion of natural deposits | |
| Synthetic Organic Contaminants | | | MCL | MCLG | | | | |
| Di(2-ethylhexyl)phthalate (5) | 2021 | ppb | 6 | 0 | RAA=2 | ND – 2.0 | Discharge from rubber and chemical factories | NO |
| Unregulated Contaminant Monitoring (10) | | | MCL | MCLG | | | | |
| Sodium (2) | 2021 | ppm | N/A | N/A | 34.8 | 27.1 – 34.8 | Erosion of natural deposits; road-salt runoff; contained in water treatment chemicals. | N/A |
| Metachlor (5) | 2021 | ppb | N/A | N/A | 0.10 | ND – 0.10 | Used as an herbicide for weed control on agricultural crops | N/A |
| Chlorate (2) | 2021 | ppb | N/A | N/A | 450 | 130 - 450 | By-product of drinking water chlorination | N/A |
| Manganese (2) | 2021 | ppm | N/A | N/A | 0.018 | 0.001 - 0.078 | Erosion of natural deposits; runoff from orchards | N/A |

*The data presented in this table is from the most recent testing done in accordance with regulations. Test results are from the Portsmouth Water and Fire District’s distribution system unless otherwise noted by the footnotes.

Water Quality Table Footnotes

- (1) In 2021, the District collected 546 samples that were tested for Total Coliform Bacteria. All samples were negative.
- (2) Measured after treatment at the Newport Water Department Lawton Valley Treatment Plant.
- (3) Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.
- (4) Detected level is Stage 2 DBPR highest locational running annual average. *Some people who drink water containing TTHM's in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*
- (5) Measured in the Newport Water Department raw water reservoirs prior to treatment.
- (6) Measured in the Newport Water Department raw water supply and entry points to the distribution system.
- (7) The detected level indicates the 90th percentile value of the 33 samples obtained at 33 high-risk homes. None of the samples exceeded the Action Level.
- (8) Fluoride is added to the water to help prevent tooth decay in children.
- (9) The detected level indicates the 90th percentile value of the 33 samples obtained at 33 high-risk homes (one home was resampled). One of the 33 samples exceeded the Action Level.
- (10) Unregulated contaminants are those that do not yet have a primary drinking water standard set by the US EPA. The purpose of monitoring for these contaminants is to help the US EPA develop regulatory decisions for these contaminants.